

DEPARTMENT OF THE ARMY
Omaha District, Corps of Engineers
106 South 15th Street
Omaha, Nebraska 68102-1618

:NOTICE: Failure to acknowledge : Solicitation No. DACA45 02 B 0010
:all amendments may cause rejec- :
:tion of the bid. See FAR : Date of Issue: 08 Jul 2002
:52.214-3 of Section 00100 : Date of Opening: 07 Aug 2002

Amendment No. 0001
29 July 2002

SUBJECT: Amendment No. 0001 to Specifications and Drawings for Construction of
Repair Roof Building 20, US Army Reserve Center, 21st & Woolworth,
Omaha, NE
Solicitation No. DACA45 02 B 0010.

TO: Prospective Bidders and Others Concerned

1. The specifications and drawings for subject project are hereby modified as follows (revise all specification indices, attachment lists, and drawing indices accordingly).

a. Specifications. (Descriptive Changes.)

(1) Section 00800 Page 7, delete paragraph 1.15 SIGN, also delete the sign details from the list of attachments on page 00800 Page 2.

(2) Section 07320 Page 6, paragraph 2.1.3.1, line 3, delete "1-1/2 inches long" and substitute "1 inch long".

b. Drawings (Not Reissued). The following drawing sheets are revised as indicated below with latest revision date of 29 July 2002. These drawings are not reissued with this amendment.

(1) Sheet AC.1, Cover Sheet, General Notes, add the following new note:

"3. Buildings 6 and 24 no longer exist."

(2) Sheet A.1, Scope of Work Notes,

A) Note 1, line 9, delete "IT IS NOT" and substitute "IT IS"

B) Note 4, line 1, delete "DRILL 1/8-INCH HOLE" and substitute "DRILL 1/4-INCH HOLE"

C) Note 6, delete the next to the last sentence and substitute the following "EXISTING TIES SHALL FIRST BE REINSTALLED ON THE HIGH ROOF AND THE WEST AND NORTH ROOF SLOPES OF THE LOWER ROOFS."

(3) Sheet A.1, General Notes, Note 6, delete "REGULATRIONS" and substitute "REGULATIONS".

(4) Sheet A.2, Scope of Work Notes, delete Note 8 and substitute the following:

"8. AS A PART OF THIS SCOPE OF WORK ESISTING AND NEW - EAVE FASCIA DOWNSPOUTS, GUTTERS, CHIMNEY SUPPORTS, SNOW GUARDS AND ROOF FLASHINGS IF PAINTED IN THEIR EXISTING FORM SHALL BE PAINTED TO MATCH EXISTING TRIM ITEMS."

2. This amendment is a part of the bidding papers and its receipt shall be acknowledged on the Standard Form 1442. All other conditions and requirements of the specifications remain unchanged. If the bids have been mailed prior to receiving this amendment, you will notify the office where bids are opened, in the specified manner, immediately of its receipt and of any changes in your bid occasioned thereby.

a. Hand-Carried Bids shall be delivered to the U.S. Army Corps of Engineers, Omaha District, Contracting Division (Room 301), 106 South 15th Street, Omaha, Nebraska 68102-1618.

b. Mailed Bids shall be addressed as noted in Item 8 on Page 00010-1 of Standard Form 1442.

3. Bids will be received until 2:00 p.m., local time at place of bid opening, 07 Aug 2002.

U.S. Army Engineer District, Omaha
Corps of Engineers
106 South 15th Street
Omaha, Nebraska 68102-1618

29 July 2002
MFS/4411